


Investigation and Correction of the High Thermal to N-16 Ratio in the Southwest Lobe in the ATR



*Marya Morrison
TRTR 2017*

Overview


- Investigation Team
- Overview of N-16, WPC Systems
- Issues of High Thermal to N-16 Ratio
- Formal Trouble Shooting Plan
- Some Trending and Data Review
- Changes to N-16 System and Water Power Calculator
- Actions Taken for Problem Resolution

Team Approach

- System Engineering
 - Bob Fulks (Lead), Jerry Mullen, and Darrin Robinson
- Reactor Instrument Technicians
 - Rick Sistrunk, Brad Packham, Russell Loveday
- Operations
 - Ken Schreck, Veryl Kirkpatrick, Dave Kahn, Phil Cox, and Various Other Crew Members
- Reactor Engineering
 - Marya Morrison, Daren Norman, Rose Holtz, Ryan Little
- Instrument Shop
 - Instrument Technicians for N-16 Flow and WPC
- Maintenance
 - Fitters for N-16 Tube Change out
- S&T
 - Chris Brooks
 - Joe Nielsen
- Walsh Engineering
 - Theron Jensen

N-16 System Description


- Lobe Power Calculation and Indication System (LPCIS)
 - Uses activated N-16 that is measured at various locations within the core
 - 4 Inboard (18.74")
 - 4 Outboard (19.00")
 - 2 Center
 - Determines lobe and quadrant powers
 - Constrained powers determined by solving a 5×10 matrix
- Threshold reaction
 - O-16 (n,p) N-16
 - Greater than 10 MeV neutrons
 - Cross section is about 20 millibarn
 - Unlike most N-16 system it uses the beta decay and not the gamma decay




N-16 System Detectors Located on Motor Floor



N-16 System Spectral Considerations



N-16 System Spectral Considerations




N-16 System Mathematics

- Lobe powers are calculated based on the following equation:

$$M_j N_j = \sum_{i=1}^5 c_j^i P_i$$

- M are the multipliers for each detector (10 values - j)
- N are the detector signals from the ion chambers (10 values - j)
- c are the coefficients for lobe and each detector (50 values - i, j)
- j is the detector of concern
- i is the lobe of concern




Lobes						
NW(1)	NE(2)	C(3)	SW(4)	SE(5)		
$C_{1,1} P_1 +$	$C_{1,2} P_2 +$	$C_{1,3} P_3 +$	0	+ 0	= M_1	(N_1) :North N-16 Monitor 1
0	+ $C_{2,2} P_2 +$	$C_{2,3} P_3 +$	0	+ 0	= M_2	(N_2) :North-East N-16 Monitor 2
0	+ $C_{3,2} P_2 +$	$C_{3,3} P_3 +$	0	+ $C_{3,5} P_5 =$	M_3	(N_3) :East N-16 Monitor 3
0	+ 0	+ $C_{4,3} P_3 +$	0	+ $C_{4,5} P_5 =$	M_4	(N_4) :South-East N-16 Monitor 4
0	+ 0	+ $C_{5,3} P_3 +$	$C_{5,4} P_4 +$	$C_{5,5} P_5 =$	M_5	(N_5) :South N-16 Monitor 5
0	+ 0	+ $C_{6,3} P_3 +$	$C_{6,4} P_4 +$	0	= M_6	(N_6) :South-West N-16 Monitor 6
$C_{7,1} P_1 +$	0	+ $C_{7,3} P_3 +$	$C_{7,4} P_4 +$	0	= M_7	(N_7) :West N-16 Monitor 7
$C_{8,1} P_1 +$	0	+ $C_{8,3} P_3 +$	0	+ 0	= M_8	(N_8) :North-West N-16 Monitor 8
$C_{9,1} P_1 +$	$C_{9,2} P_2 +$	$C_{9,3} P_3 +$	$C_{9,4} P_4 +$	$C_{9,5} P_5 =$	M_9	(N_9) :Center N-16 Monitor 9
$C_{10,1} P_1 +$	$C_{10,2} P_2 +$	$C_{10,3} P_3 +$	$C_{10,4} P_4 +$	$C_{10,5} P_5 =$	M_{10}	(N_{10}) :Center N-16 Monitor 10

N-16 System Mathematics

- Lobe powers are calculated based on the following equation:

$$M_j N_j = \sum_{i=1}^5 c_j^i P_i$$

- M are the multipliers for each detector (10 values - j)
 - N are the detector signals from the ion chambers (10 values - j)
 - c are the coefficients for lobe and each detector (50 values - i, j)
 - j is the detector of concern
 - i is the lobe of concern
- System of 5 equations used for determining lobe powers:
 - Based on Least Squares Method
 - Solved in real time during operation
 - Does not included thermally constrained correction



$$P_1 \sum_j C_{j,1} C_{j,1} + P_2 \sum_j C_{j,1} C_{j,2} + P_3 \sum_j C_{j,1} C_{j,3} + P_4 \sum_j C_{j,1} C_{j,4} + P_5 \sum_j C_{j,1} C_{j,5} = \sum_j C_{j,1} M_j N_j$$

$$P_1 \sum_j C_{j,2} C_{j,1} + P_2 \sum_j C_{j,2} C_{j,2} + P_3 \sum_j C_{j,2} C_{j,3} + P_4 \sum_j C_{j,2} C_{j,4} + P_5 \sum_j C_{j,2} C_{j,5} = \sum_j C_{j,2} M_j N_j$$

$$P_1 \sum_j C_{j,3} C_{j,1} + P_2 \sum_j C_{j,3} C_{j,2} + P_3 \sum_j C_{j,3} C_{j,3} + P_4 \sum_j C_{j,3} C_{j,4} + P_5 \sum_j C_{j,3} C_{j,5} = \sum_j C_{j,3} M_j N_j$$


$$P_1 \sum_j C_{j,4} C_{j,1} + P_2 \sum_j C_{j,4} C_{j,2} + P_3 \sum_j C_{j,4} C_{j,3} + P_4 \sum_j C_{j,4} C_{j,4} + P_5 \sum_j C_{j,4} C_{j,5} = \sum_j C_{j,4} M_j N_j$$

$$P_1 \sum_j C_{j,5} C_{j,1} + P_2 \sum_j C_{j,5} C_{j,2} + P_3 \sum_j C_{j,5} C_{j,3} + P_4 \sum_j C_{j,5} C_{j,4} + P_5 \sum_j C_{j,5} C_{j,5} = \sum_j C_{j,5} M_j N_j$$

WPC System


- Water Power Calculator (WPC) uses flow rates and temperature increase to determine reactor power (simple calorimetric)
 - Flow is split into four quadrants when exiting the reactor
 - Thermal power measurement limited to quadrants
 - Total thermal power is very accurate with quantifiable uncertainties
 - There is some WPC uncertainty due to potential cross flow
- WPC power is used to correct N-16 lobe powers (Constrained)
 - An eleventh equation is inserted into the LPCIS matrix to cause the solution of N-16 lobe powers to equal total power
 - WPC and N-16 compared for system heath assessment

- SAR and TSR Safety Parameters that are implemented in the CSAP
 - Fission Density
 - Effective Plate Power (EPP)
 - Effective Point Powers
- CSAP limits are based on lobe powers
- To ensure that safety limits are not exceeded power levels are lowered if they exceed the specified limits provided in the CSAP



Problem Statement

The Southwest Quadrant (Q-3) WPC to N-16 Ratio has been operating higher than the Maximum Limit of 1.077




Formal Trouble Shooting Plan (Robert Fulks)

- Troubleshooting plan per MCP-6045
- The thermal to N-16 power ratio in the Southwest Quadrant was exceeding the maximum limit of 1.077 (no EPP limit)
 - Cycle 157D-1 exceeding limit at the beginning of cycle (~ 36 days)
 - Cycle 157A-1 exceeded limit at the end of cycle (~ 20 days)
- The thermal to N-16 power ratio in the Southwest Quadrant had exceeded the nominal limit of 1.035 (no EPP limit)
 - Cycle 157D-1 exceeding limit at beginning of cycle (59 days)
 - Cycle 157C-1 exceeded limit for the entire cycle (5 days)
 - Cycle 157A-1 exceeded limit for the entire cycle (37 days)
- Pertinent Information
 - The power ratio has been increasing over the past several cycles
 - The Southwest power ratio is by design more heavily weighted with Center N-16 power signal than the other quadrants


Ratios for some Recent Cycles

Thermal Power to N-16 Unconstrained Quadrant Power Ratio SW Quadrant Comparison by Cycle




Ratios for some Recent Cycles

Thermal Power to N-16 Constrained Quadrant Power Ratio SW Quadrant Comparison by Cycle



Normalized Ratios for Two Cycles



Formal Trouble Shooting Plan (Robert Fulks)

➤ Actions performed

- ✓ Verified N-16 multipliers were correct for the flow source
- ✓ Verified N-16 flow rates (inlet and outlet) at 1.15 GPM
- ✓ Verified N-16 flow orifices cleaned and flushed (ref. WO-205278)
- ✓ Switched to LDW to verify BPD was not the cause of the problem
- ✓ Verified High/Low Gain Switch was in Low position
- ✓ Switched from SW to spare beta chamber
- ✓ Performed DOP-7.7.19 N-16 flow calibration check
- ✓ Performed preliminary N-16 to Water Power Calculator data point checks
- ✓ Performed comparison between current data and historical data
- ✓ When in TEST mode, the Center N-16 instrument historically indicates Out-of-Spec low. (Calibrates in spec when in Operate mode.)
- ✓ All mechanical and electrical components (pipe, orifice, D/P detector, wires interconnections, power supplies, amplifiers, and N-16 detector) have been verified satisfactory
- ✓ Completed DOP-7.7.12, N-16 Chamber Sensitivity Checks, twice, once in Cycle 157C-1 and once in 157D-1, both with satisfactory results.
- ✓ Replaced Southeast N-16 reentrant tube.
- ✓ Added south N-16 channel by running it through the spare detector

Changes of Interest to the N-16 and WPC

- Reentrant Tubes Replacement Dates:

Southwest - August 2012

West - August 2012


South - May 2013

East - July 2013

Northeast - October 2013

North - October 2013

Southeast - May 2015




- Center Flux Trap Baffle and N-16 aluminum reentrant tubes replaced with stainless steel – August 2012

- Water Power Calculator Update and new RTD calibration curves – August 2012

Actions Taken for Problem Resolution

- Replaced of the Southwest reentrant tube because a potential bypass flow
- Gathered RDAS data and assessed the WPC and N-16 detector signals
- System engineering evaluated new multipliers. The LPCIS was be taken out-of-service and multipliers were tested
 - (M_{10} expected to increase by $\sim 23\%$)
- Flux wire data was assessed to identify potential shifts in the thermal to fast ratios
- Numerical Modeling indicated changes to Multipliers needed for Cycle 158A-1 due to experiment demands
- Evaluated using Northeast flow channel for N-16 Chamber Sensitivity Tests





Idaho National Laboratory