

# **BORAL<sup>®</sup> Spent Fuel Pool Coupon Testing at the University of Texas, Austin**

P. M. Whaley  
Associate Director, NETL  
University of Texas at Austin



# Overview

- Nuclear Power Plant Spent Fuel & BORAL
- OPPD, FCNS Testing
- Process Overview
- Testing at NETL
- Results & Conclusions



# Spent Fuel & Nuclear Industry

- Spent fuel reprocessing option eliminated in 1970's
- Nuclear Waste Policy Act of 1982
  - USDOE contracted to remove spent fuel
  - Utilities pay about 2 cents/rated-kW per quarter
  - National repository scheduled for 1998
- Absence of national repository spurred
  - Development of on-site storage
  - Cooling in spent fuel pools followed by dry storage
  - Modification of SFPs to improve capacity during cooling



# NRC Guidance

- April 1978: Review and Acceptance of Spent Fuel Storage and Handling Applications (NRC)

“Prior to 1975, low density spent fuel storage racks were designed with a large pitch, to prevent pool criticality ...”

*for modifications to increase capacity by decreasing pitch* “Credit may be taken for the neutron absorption in structural materials and in solid materials added specifically for neutron absorption, provided a means of inspection is established.”

***“...coupon or other type of surveillance testing shall be performed on a statistically acceptable sample size on a periodic basis throughout the life of the racks to verify the continued presence of a sufficient amount of neutron absorber in the racks...”***



# BORAL<sup>®</sup>

- Precision, hot-rolled, plate composite
  - Al cladding (1100 series)
  - Core of mixed Al and B<sub>4</sub>C particles
- Within practical limits, can be machined & welded
- 35 years production history
- Used at 70 power plants & 11 RRs worldwide



# History with NRC Licensees

- Various LERs from surveillances & inspections
- Generic Safety Issue 196: Boron Degradation
- IN 2009-26: Degradation of Neutron-Absorbing Materials in the Spent Fuel Pool
- **ASTM C 1187-91 (1999) Standard Guide for Establishing Surveillance Test Program for Boron-Based Neutron Absorbing Material Systems for Use in Nuclear Spent Fuel Storage Racks**



# Surveillance Testing with Neutrons

- Measure neutron transmission
- Analyze attenuation coefficient
- ‘First principles’ approach problematic
  - Composition
  - Scattering
  - Detector & Measurement geometry
- Comparative Analysis
  - Ratios of measurements of attenuation
  - Comparison of reference, standard, or archive coupons to in-service samples

# Calculations

- Exponential attenuation

$$I_x = I_0 \cdot e^{-\rho_A \cdot \sigma \cdot \frac{N_A}{AMU}}$$

- Leads to an expression of areal density as a linear function of log of transmission ratio

$$\rho_A = -\ln \left\{ \frac{I_x}{I_0} \right\} \cdot \frac{AMU}{\sigma \cdot N_A}$$

# Simple Approximation

- Approximating  $(\rho_A, I_x: I_0)$  as a function allows development of a linear response function

$$m = \frac{\rho_{A,2} - \rho_{A,1}}{-\ln \left\{ \frac{I_{x,2}}{I_0} \right\} + \ln \left\{ \frac{I_{x,1}}{I_0} \right\}}$$

$$b = \rho_A - \ln \left\{ \frac{I_x}{I_0} \right\} \cdot m$$

- With error propagation

$$\sigma_m = (\rho_{A,2} - \rho_{A,1}) \cdot \left[ \sigma_{\ln(RATIO), ARC01}^2 + \sigma_{\ln(RATIO), ARC02}^2 \right]^{\frac{1}{2}}$$

$$\sigma_b = \left( \ln \left\{ \frac{I_{x,2}}{I_0} \right\} \cdot m \right) \cdot \left( \left( \frac{\sigma_{\ln \left\{ \frac{I_{x,2}}{I_0} \right\}}}{\ln \left\{ \frac{I_{x,2}}{I_0} \right\}} \right)^2 + \left( \frac{\sigma_m}{m} \right)^2 \right)^{\frac{1}{2}}$$

# Omaha Public Power District, Fort Calhoun Station Unit 1

## *RE-ST-RX-004 Surveillance test*

### *BORAL Sample Coupon Retrieval and Testing*

- Technical Specification 3.2: *five-year test interval*
- Neutron Attenuation Tests - An instrumental method of chemical analysis for Boron-10 content using a non-destructive technique in which the percentage of thermal neutrons transmitted through the panel is measured and compared with pre-determined calibration data.
- 7.23 The irradiated and archive coupons are sent to a qualified independent laboratory to obtain for the irradiated coupon, neutron attenuation measurements, specific gravity measurements, and, if required, detailed photographic documentation...




# Qualified Independent Laboratories

- University of Michigan Ford Nuclear Reactor (diffracted beam station)
- Kansas State University (tangential thermal beam)
- University of Texas at Austin

## Nuclear Engineering Teaching Laboratory

- Beam Port 3
- 6 m curved guide (three 2 m sections)
  - 300 meter radius of curvature
  - 1000 Å <sup>58</sup>Ni coating,
  - characteristic wavelength 2.7 Å, 11 meV cutoff
- 80 cm capillary focusing assembly (gain from 3 to max 4)
- Neutron energy 0.008-0.0085 eV (94-98°K)
- Intensity  $5 \times 10^6$  n/cm<sup>2</sup>-s (Cd ratio 81,000)


# NETL Beam Ports




# Preparation & Setup

- Coupons received (no data, certification, or procedure)
- System optically aligned
- Detector plateau performed
- Calibration for response versus power level
  - 20 kW did not saturate detector in bare beam
  - Shielded count times of 40 sec provided >10K events

Detector Voltage



# Mark I: KISS






# Measurement (Mark I)

- Transmission testing completed with data:
  - Three elevations for each sample/coupon
  - Five positions at each elevation
  - Three times for each measurement location
- Observations
  - Bare beam extremely stable across 60 measurements
    - Average 101173, max 1011858, min 1011521 events
    - Standard deviation 0.007%
  - Standard deviations 2.9% for both archive samples
  - Coupon sample attenuation not bracketed by archive sample attenuation values
  - More variability in 54 coupon sample measurements
    - Average 20293, max 22284, min 18390 events
    - Standard deviation 4%

# Received Procedure

- Reference data
- Acceptance criteria
- Initial assay



## Initial/Reference Data

	G	K	M	Reference
ARC 01	0.0177	0.0177	0.0177	0.0174
ARC 02	0.0169	0.0166	0.0167	0.0168
Coupon	0.0161	0.0165	0.0163	0.0163

“Reference” is chemical analysis

Acceptable Range: 0.0155 to 0.0163



# Evaluation of Results

- Calculated sample areal densities
  - 0.01628 to 0.01668
  - More than  $\frac{1}{2}$  of the 9 readings exceeded tolerance
  - Values in the G/M/K positions (2 orientations)  
0.01629 (0.01616), 0.01629 (0.01628), 0.01668
- Compared to original transmission data,
  - One orientation matched original assay
  - Center areal density 1% higher than assay
- Original center value assay (0.0165) out of tolerance
- Original measurement indicated non uniform boron



# Analysis


- FCNS requested comprehensive error analysis
  - Center areal density outside  $1\sigma$  band
- Sample manipulation not overly precise
- Small, divergent beam could lead to
  - Relative position changes between measurements
  - Different optical paths between measurements
  - Variations in scattering contribution between measurements



# Mark II

- Developed & used a fixture
  - Detector positioned securely close to sample
  - Sample position precision improved
- Detector aligned to be fully illuminated in beam using neutron radiography camera
- *Detector failure* potentially challenging previous work

# Sample Jig



# Fixture in Place



# Detector Alignment





# Results and Conclusions

- Test results were essentially identical
- An out of tolerance condition was observed, but appears to be an artifact of the test specification
- Based on original transmission data, there is strong indication that the boron content of the coupon has not degraded by service conditions
- The NETL BP 3 neutron beam is well suited for spent fuel coupon transmission testing
  - Stability
  - Neutron energy
  - System configuration