

OPERATIONAL IMPACTS OF HIGH REACTIVITY TARGETS OR THE PERILS OF RELEARNING OLD LESSONS IN A NEW REGULATORY ENVIRONMENT.

Mark Trump & Brenden Heidrich & Daniel Beck



Research Problem / Opportunity

- The United States currently faces a shortage of medical isotopes for both clinical use and research and development.
- Funding is available!
- ⁶⁴Cu and ⁶⁷Cu are two key isotopes identified as being in short supply; their emissions and their moderate half-lives make them effective for diagnosis and treatment.



ENGINEERING CENTER

OPERATIONS PROBLEM / OPPORTUNITY

- Experimenters are unfamiliar with experiment or techniques its new to them
- High Reactivity, Heat Generation, High Radiation, "New" Materials
- Research/Experiment hypothesize, trial error
- Son-routine experiment becomes routine
- Time pressure, holding up research at RESEARCH reactor
- Oversight and conservatism when to say NO



Research Isotopes of Interest

| ⁶⁴ Cu | ⁶⁷ Cu |
|---------------------------------|-------------------------------|
| t _(1/2) = 12.7 hours | t _(½) = 61.8 hours |
| β+ ~278 keV (17.9%) | β-~~141 keV (100%) |
| EC (43.1%) | γ 184.6 keV (48.7%) |
| β⁻ ~191 keV (39.0%) | 93.3 keV (16.1%) |
| | 91.3 keV (7.0%) |
| | |

PET scans and tracking Cancer treatment and metabolic disorders medical imaging




Research Methods of Production

| Method | Reactions | (+) Advantages | (-) Disadvantages |
|-------------------------------------|--|--|--|
| Charged particles | ${}^{64}_{28}Ni + {}^{1}_{1}p \rightarrow {}^{64}_{29}Cu + {}^{1}_{0}n$ ${}^{64}_{28}Ni + {}^{4}_{2}\alpha \rightarrow {}^{67}_{29}Cu + {}^{1}_{1}p$ | Target separationsHigh cross sectionsHigh specific activity | Limited accelerator time Cost of ⁶⁴Ni is high and quantities are limited |
| Simple (n _{thermal} ,γ) | ${}^{63}_{29}Cu + {}^{1}_{0}n \rightarrow {}^{64}_{29}Cu$ ${}^{66}_{29}Cu + {}^{1}_{0}n \rightarrow {}^{67}_{29}Cu$ | Readily abundant thermal neutrons High cross sections | No chemical separation: Isotopic dilution Low specific activity |
| Reactor production | ${}^{64}_{30}Zn + {}^{1}_{0}n \rightarrow {}^{64}_{29}Cu + {}^{1}_{1}p$ ${}^{67}_{30}Zn + {}^{1}_{0}n \rightarrow {}^{67}_{29}Cu + {}^{1}_{1}p$ | Target separations High specific activity Use of large targets Available reactors | Low cross sections Lower n_{fast} flux |

CORE LOADING 55








| | Thermal Flux | |
|-------------------------------------|--------------|----------|
| Condition | 0-1 eV | 1-20 MeV |
| Water-filled | 100% | 100% |
| Air (Bare target) | 80% | 126% |
| Air (0.5 mm Cd shield) | 42% | 123% |
| Air (2.0 mm ¹⁰ B shield) | 24% | 113% |

IRRADIATION FACILITY DESIGN





ENGINEERING CENTER

SHIELDED IRRADIATION CAPSULES

Rev.1 \$1.20

Rev.2 \$1.49





Operations had concerns over reactivity of holders



Capsule Body

IRRADIATION CAPSULE (REV. 3 \$.80)



Capsule Cap



REVIEW CONCERNS TESTS AND PREDICTIONS

Review Concern – Heat Production --- Swelling

| | | MCNP F6 tally results | | |
|--------|----------|-----------------------|----------|-------------|
| Rev. 2 | mass (g) | mev/g/source particle | MeV/s | Watts |
| sides | 66.9 | 1.37E-04 | 7.15E+14 | 114.5 |
| bottom | 22.5 | 1.33E-04 | 2.34E+14 | 37. |
| | | | Tota | l 152 |
| Rev. 3 | | | | |
| sides | 35.9 | 1.89E-04 | 5.3E+14 | 85. |
| bottom | 14.0 | 2.03E-04 | 2.2E+14 | 35. |
| | | | Tota | 12 |
| Rev 4 | | | | |
| sides | 26.2 | 1.89E-04 | 3.9E+14 | 62. |
| bottom | 3.31 | 3.02E-04 | 7.8E+13 | 12 . |
| plug | 6.29 | 1.66E-04 | 8.1E+13 | 1 3. |
| | | | Tota | 8 |







REVIEW CONCERNS TESTS AND PREDICTIONS

Review Concern – Heat Production --- Swelling

Sample Holder Temperature vs. Reactor Power in Dry Tube







REACTIVITY CONCERNS PREDICTIONS AND CHECKS

| Design | MCNP | Measurement | Deviation |
|--------|---------|-------------|-----------|
| rev 1 | -\$1.36 | -\$1.20 | 13% |
| rev 2 | -\$1.53 | -\$1.49 | 3% |
| rev 3 | -\$0.79 | -\$0.80 | -1% |
| rev 4 | n/a | -\$0.12 | n/a |


Flux maps OK with Conservative affect on Nuclear Instruments



FLUX RUNS

2 hour flux run in central thimble

- Solution State State
- Could not get the sample holder open Boron Nitrate plug sealed itself




Couple days later another run with slight design change..... Same problem

Third time is a charm Now routine....?



OPERATIONAL EVENT HIGH POWER SCRAM - APRIL 16

1415 ADO assumes RO watch to get sample going.
1501 Reactor @ 1 MW with sample in central thimble.
1520 Watch Team turnover to "new" staff SRO and student RO.



1650 RO/SRO discuss shutdown vs. pulling sample. Pulling low reactivity timed samples at low power is "routine".

1701 Sampled pulled by SRO, High power scram (106% digital, 108% analog) Peak power 1.328MW Fuel Temp increase 1 degree C



OPERATIONAL EVENT ACTIONS AND CAUSES

Immediate actions


- Reactor secured and tagged out
- Management notified
- Operational stand-down, critique and event review

Causes

- Mindset, group think, habit intrusion,
- Experiment authorization inadequacy,
- Experiment authorization procedure inadequacy

Follow-up actions

- Experiment authorization suspended, all others reviewed for adequacy/suspended
- Experiment authorization procedure under revision
- Operator training on prompt jump and safety analysis






REPORTABILITY DETERMINATION

All systems performed as designed, experiment in compliance with TS - *Initially determined not reportable* Student SRO brought up concern with literal compliance

- For Non-Pulse Mode Operation TS 3.1.1.c. states "The maximum power level shall be no greater than 1.1 MW (thermal)."
- Basis is to protect Steady State decay heat assumptions and source term.

NRC position, report now, withdraw if not reportable. Reported prior to the end of the next business day.






TEST REACTOR EXCEEDED LICENSED POWER LIMIT DURING A SCRAM

The following information was excerpted from an email from the licensee:

On April 16, 2013 at 1701 EDT, the research test reactor automatically shutdown from 100% power (1 MW) due to a valid high power condition. The duty Senior Reactor Operator removed a timed irradiation sample from the core that added positive reactivity. Both the digital (non-safety system) and the analog safety system acted on the high power condition and initiated the shutdown. All systems functioned as designed. The short duration power transient reached a peak power of about 1.3 MW. There was no increase in radiation levels, personnel radiation exposure, or release of radiation from the facility. No emergency event entry criteria were met. The plant was placed in a secured condition and an event review investigation was conducted.



The event is (potentially) reportable in that the Maximum Power Level observed during the short duration (< 1 second) transient exceeded the steady state power limit for non-pulse mode operation as described in Technical Specification(TS) 3.1.1 Non-pulse mode operation sub-section b. The maximum power level shall be no greater than 1.1 MW (thermal).

The reactor was returned to routine service at approximately 1300 EDT on April 17, 2013.



THOUGHTS, QUESTIONS,...

FALLOUT


end

Operators are the <u>last line</u> of defense, we fail them every time we challenge them.

All our reviews, concerns, and plans did not prevent this event. They *knew* better, but had to learn again.

Experiments are trials and errors, there were two more minor events in this experiment series. We are trying to relearn a production method from years ago...

Questions? Feedback?





ALARA New Danger Tag

DANGER VERY HIGH

RADIATION SOURCE



RADIATION TIME DATE LEVEL [R/HR] 5/8 12pm (t=0) 10,000 5/8 6pm (t=6) 1.250 5/9 12pm (t=24) 0.420 5/10 12pm (t=48) 0.150

DO NOT REMOVE

BEFORE:

_5/10/2013___

Irradiation Capsule (Rev. 4a) [Dry Tube Location only] 1st Flux Run 5/17/2013 Dry Tube 2 1000kW for 120min 27grams Al-6061 33grams BN AuAl & Ti wire

00

5

18

19

20

N

N

Irradiation Capsule (Rev. 4b) [Dry Tube Location only]

2nd Flux Run 5/24/2013 Dry Tube 1 1000kW for 6min. 14grams Al-6061 33grams BN AuAl & Ti wire




Irradiation Capsule (Rev. 4a) [Dry Tube Location only]






MEASUREMENTS

- 1. Reactivity Worth in water-filled CT = -\$0.80 (rev. 3)
- 2. Heat Build-up = 95°C at 1MW (Rev 1 & air-cooled)
- 3. Flux Measurements







FLUX MEASUREMENT IRRADIATION

Two shielded capsules (rev. 4) irradiated in two dry tube locations (E4 and E13)

- DT1: AuAl and Ti wires
- DT2: 0.7gm of natural Zinc Oxide
- 2 hours at 1MW

2nd Flux Run 5/24/2013 Dry Tube 1 1000kW for 6min. 14grams Al-6061 33grams BN AuAl & Ti wire

BATE 5/24/13 ... BY B

RUXRUN

2nd Run – natural zinc 5/24/2013 Dry Tube 2 1000kW for 6min. 14grams Al-6061 33grams BN < 1 gram Zn0