


NBSR Path to Equilibrium Core




Osman Sahin Celikten,
Ph.D., Nuclear Engineer
NIST Center for Neutron Research,
100 Bureau Dr.,
20899 Gaithersburg, MD, USA

Certain commercial equipment, instruments, or materials are identified in this study in order to specify the experimental procedure adequately. Such identification is not intended to imply recommendation or endorsement by the National Institute of Standards and Technology, nor is it intended to imply that the materials or equipment identified are necessarily the best available for the purpose.


- **Introduction**
 - National Bureau of Standards Reactor
 - Startup Core
- **Limitations**
 - Technical Limitations
 - Administrative Limiting Conditions
- **Alternative Fuel Management Scheme Framework**
- **Recovery Fuel Management Scheme**
- **New Startup Core – Cycle 655**
- **Cycle 656**
- **Summary and Discussion**

- **NCNR is one of the USA's primary resources for neutron research**
- **First criticality in 1967**
- **Originally designed for 10 MW operation**
 - Relicensed at 20 MW
- **Heavy water cooled and moderated**
- **February 3, 2021, partial fuel melting incident**
- **More than 2 years recovery period**
- **Restart authorized in March, 2023**
- **Currently in low-power testing mode**



Introduction

- After the incident in February 2021, debris found on several fuel elements
- All fuel in Cycle 655 are deemed unusable
- Original Fuel Management Scheme (OFMS)
- New core can be constructed utilizing
 - Burned elements (mostly 7th-Cycle)
 - Limited number of fresh fuel elements
- Limitations
 - Technical
 - Administrative



- **The confines of NBSR Technical Specifications and UFSAR**
 - Up to 45.0 kilograms ^{235}U of any enrichment & less than 5.0 kilograms fresh.
 - NBSR is authorized steady-state power levels up to a maximum of 20 megawatts (thermal).
 - The reactor fuel cladding temperature shall not exceed 842°F (450°C) for any operating conditions of power and flow.
 - The maximum core excess reactivity shall not exceed 15% $\Delta\rho$.
 - The reactor shall not be operated unless the shutdown margin provided by the shim arms is greater than 0.757% $\Delta\rho$ (\$1.00) with:
 - In any core condition, and
 - All movable experiments in their most reactive condition

- **The confines of NBSR Technical Specifications and UFSAR**
 - The reactor shall not operate unless all grid positions are filled
 - The average fission density shall not exceed 2×10^{27} fissions/m³ (73% theoretical burnup)
 - The reactivity insertion rate shall not exceed $5 \times 10^{-4} \Delta\rho/\text{sec}$.
 - The minimum CHF is dictated by the 80/80 statistic
 - minimum CHF of 1.19 for an 80% probability of no departure from nucleate boiling (DNB)
 - 1.78 for a 99.9% probability of no DNB

- **The NBSR inventory has limited number of 7th cycle elements**
- **Only limited inventory being unirradiated or not self-protecting. (10 CFR 73.60 for details)**
- **Time constraints**


Alternative Fuel Management Scheme Framework

➤ Why is it developed?

- For trial multiple schemes
- Easy to assess
- Reassessment of reloading in the operation
- Using for the following cycles

➤ Assessed Criteria

- Excess reactivity at SU
- Enough Shim Reactivity (Worth)
- Maximum power peaking
- Minimum CHFR
- Minimum OFIR





Cycle States
SU
BOC
Q2
MOC
Q4
EOC

License Amendment Requests (LARs)




- “Operate with Debris in the Primary Coolant System” (ML23020A911)
- “Alternative Fuel Management Scheme” (ML23055A300, ML23033A114, ML23033A115, and ML23033A119)




Core Loading Optimization Strategy

- **Metaheuristic combinatorial optimization**
- **Optimize excess reactivity, maximum PPF, and core PPF balance for a cycle**
- **Fast-response surrogate model of MCNP**
 - Voting ensemble regressor for robustness
- **Single-solution model (Exploitation)**
 - Updating utility tables based on the reward/penalty
- **Population model (Exploration)**
 - Recombination of utility tables of better solutions




Core Loading Optimization Strategy


- **Optimizer model is fully coupled with MCNP**
 - Update initial loading file, processing of MCNP output
- **Active learning strategy**
 - Propose core loading schemes to improve the surrogate model
 - Re-train the surrogate model if necessary
- **Search for the optimal core**
 - Longer search to approximate the global optimum of the surrogate model
 - Run MCNP for actual values



New Startup Core – Cycle 655




Opt53




M5317

Cycle 656



Case125



M12510

- **Although All technical and administrative limitations, NBSR cores were constructed with seventeen 7th-cycle and thirteen fresh fuel elements and became critical on March 16, 2023, after Feb 2021.**
- **The measurements and the calculated results with AFMS were acceptable. Calculated results are conservative**
- **A core loading framework was developed:**
 - Alternative Fuel Management Scheme (AFMS)
- **An optimization algorithm was developed by using Machine Learning algorithms (Not included in the AFMS procedures, used internally for initial load determination only):**
 - AFMS Optimizer
 - Automatically configure cores, try, and assess.
 - Gradually learning by each core configuration

- **Cycles 655 and 656 were prepared with AFMS**
- **Waiting for the full power operation to complete the next cycles**
- **Expecting the approximate OFMS loading can be reached after 662 but the OFMS loading mass could be reached 2 cycles earlier if the *4 Fuel Element Case is adopted***



NIST