

Lessons Learned using a PLC for Process Control

M. Middleton, R.E. Williams, Bryan Evers and Dan Khan
NIST Center for Neutron Research

TRTR 2016
August 25, 2016

Lessons Learned using a PLC for Process System Control

Introduction to NIST NCNR Cold Source

PLC control of the Cold Neutron Source

Basic understanding of PLC Data Input and Output


Reactor Rundown Associated with Cold Neutron Source

Regulatory Issue Summary 2016-05, Embedded Digital Devices


Communication Fault

Software Common Cause Failure

Cut-away View of the NBSR Core



2015




Bold indicates new or re-located, upgraded instruments.




NRC OVERSIGHT

An NRC Inspector was present to observe much of the process.



The NBSR was designed with a 55-cm diameter cryogenic beam port and smaller diameter beam ports

Helium Refrigerator Cold Box Module



Refrigerator Status

Auto Operation

0

Overview

Compressor

Oil Removal

oldbox

Turbine

Vacuum System

Hydrogen System

Trends


Startup

Friday, November 04, 2005

4:06:23 PM

Cold Source Overview

RX POWER 19.843 MW




Overview Compressor Oil Removal Coldbox Turbine Vacuum System CS Hydrogen PW Hydrogen **CNS Overview** Trends Status Startup

Tuesday, April 09, 2013

10:16:51 AM

Vacuum System



Communication Error, Cycle power to Unit: Assert in File ApexHW.cpp Line 845

Date	Rack #	Module	Local Error	PLC Error	FactoryTalk Error	Solution
7/17/2014	Rack 4	Comm				Cycle power
7/29/2014	Master	CPU				Reload CPU programming
8/4/2014	??	Comm	Line 845	I/O Fault		Cycle power
8/12/2014	Rack 6	Comm	"Adapter fault"	I/O Fault		Cycle power
2/7/2015	Rack 4	Comm				Cycle power
8/1/2015	Rack 5	Comm	Line 845	I/O Fault	Rack 5 Fault #40 - PW Rack Error	Cycle power
12/19/2015	Master	CPU			All numbers on HMI show blank boxes	Reload CPU programming
2/18/2016	Rack 4	Comm	Line 845	I/O Fault		Cycle power
3/11/2016	Rack 5	Comm	Line 845	I/O Fault		Cycle power
3/20/2016	Rack 5	Comm	Line 845	I/O Fault		Cycle power
3/27/2016	Rack 4	Comm	Line 845	I/O Fault		Cycle power
4/5/2016	Rack 5	Comm	Line 845	I/O Fault		Cycle power

Line 845: "Cycle power to Unit: Assert in File ApexHW.cpp Line 845."

I/O Fault: "NIST I/O Fault Rack 5 #0204 Message Timeout unconnected." (or similar)

7/13/2016, Rack 11 Comm Line 845 I/O Fault

The vast majority of the faults has been the “Line 845” failures, a coding fault that appears on the Communication module display, which is believed to be thrown by the internal apex processor on each chassis backplane. The cause of the backplane error could be the communication module, the backplane itself or literally any other component connected to it.

Actions

Check Local Network Cables

Replace Network Switch

Update Firmware on Communication Modules

Change Communication Rates

Installed Wire Shark

“Line 845” fault occurs at 4 AM one week before our next shutdown, resulting in a short rundown during the recovery. Which involves cycling the remote rack’s power supply.

Actions

Replace two communication modules

Re-Configure WireShark


Send Information on SD card to Vendor

Modify PLC Code, minimize rundown during recovery

Place Critical Components on a New Remote PLC Rack

Cold Source Overview

RX POWER 2.2E-4 MW



Overview

Compressor

Oil Removal

Coldbox

Turbine

Vacuum System

CS Hydrogen

PW Hydrogen

CNS Overview

Trends


Status

Startup

11:11:49 AM 15 CS Vac Failure: V6 >100 mTorr 15- VAC FAIL

Monday, June 13, 2016 11:12:02 AM

Vacuum System



System Status

Compressor Status

Selected Compressor **UNIT 2**
Auxillary Contact **Motor OFF**
Compressor Power **No Power**
Refrigerator Status **Normal**
Cooldown Sequence

Coldbox Status

Helium Flow **0 g/sec**
He Discharge **67 PSIA**
Turbine Speed **0 k RPM**
Turbine Inlet **295.2 K**
Turbine Fault **10**

Cold Source Temperature

C100 20.7 %O2 **UNIT 2 / BT-9**
C200 20.5 %O2
Condenser Outlet **296.5 K / 296.6 K**
Moderator Vessel **325.0 K / 329.0 K**
Cyrostat Assembly **51.0 C**

CS CryoWord 1

1 P5 OOR Clear
 2 TORYO Clear
 3 P11 LO Clear
 4 P12 OOR Clear
 5 P13 OOR Clear
 8 P14 OOR Clear
 9 TD20 HI Clear
 10 P1B OOR Clear
 11 TCND HI Clear
 12 TCND HI Clear
 13 TCND HI Clear
 14 RACK ERR Not Active

CS CryoWord 2

15 Vac Fail Active Alarm
 16 C100 H2 Clear
 17 C100 O2 Clear
 18 C200 O2 Clear
 19 VAC PWR Clear
 20 FD20 LO Clear
 21 FD20 LO Clear
 22 P1A ERR Clear
 23 P1B ERR Clear
 24 VAC ERR Not Active
 25 HE ERR Clear
 26 VAC TEMP Clear

PW CryoWord 3

27 P105 OOR Clear
 28 P108 OOR Clear
 29 P106 LO Clear
 30 P112 OOR Clear
 31 P113 OOR Clear
 34 P101A OOR Clear
 35 PW TD20 HI Clear
 36 P101B OOR Clear
 37 PW TCND HI Clear
 38 PW TCND HI Clear
 39 PW TCND HI Clear
 40 PW RACK ER Clear

PW CryoWord 4

41 PW VAC FAIL Clear
 42 D200 H2 Clear
 43 PW VAC PWR Clear
 44 PW FD20 LO Clear
 45 PW FD20 LO Clear
 46 P101A ERR Clear
 47 P101B ERR Clear
 48 PW VAC ERR Clear
 49 PW HE ERR Clear
 50 PW TCryo Clear
 51 PW VAC TEMP Clear

Cold Source Status

Reactor Power **2E-4 MW**
CS Cryo Status 1
CS Cryo Status 2
PW Cryo Status 1 **Normal**
PW Cryo Status 2 **Normal**

Unit2 (Hydrogen Pressure) BT-9

P1A 415.3 kPa **P101A 501.5 kPa**
P1A50A 43.98 psig **P1A50C 56.4 psig**
P1B 422.7 kPa **P101B 497.8 kPa**
P1A50B 45.05 psig **P1A50D 55.9 psig**

Unit2 (Vacuum) BT-9

UNIT 2 CS **Vac. Skid** **PEEWEE**
NORMAL **Condenser** **NORMAL**
VACUUM **Cryostat** **VACUUM**

Hydrogen Detectors % LFL

D200 0.0 **D100 0.0**
CS 0.0 **PW 0.0** **PWBT 0.0**

Overview

Compressor

Oil Removal

Coldbox

Turbine

Vacuum System

CS Hydrogen

PW Hydrogen

CNS Overview


Trends

Status

Startup

Monday, June 13, 2016 11:16:47 AM

Future Cold Source Layout



Embedded Digital Devices, EDD

Manufacturers are increasingly introducing digital technology into non-actuated and actuation devices that in turn are used in applications such as digital displays, motor controllers, sequencers, pumps, valve actuators, breakers, uninterruptable power supplies and emergency diesel generator controls.

Embedded Digital Devices EDD might exist in procured equipment used in safety related systems without device having been identified in procurement documentation. Related to equipment including instrumentation and controls in safety related systems.

EDDs possibly could fail to function as intended because of a latent defect, as an example in software or firmware. If a trigger results in latent software defect causing the failure of identical functions in redundant but otherwise independent systems or channels, it is a **common cause failure** across the system(channel). Defect free EDDs cannot be guaranteed with a reasonable assurance of safety, despite a quality development process and through testing.


The record of changes to the facility should show that any potential safety issue arising from the use of EDDs has been addressed adequately.

The 10 CFR 50.59 rule contains requirements for the process by which licenses may make changes to their facilities and procedures as described in the FSAR without prior NRC approval.




**ABB FLOW TRANSMITTER
MODEL #266DSH**

Average Failure Rate(Day)




Broad use of safety related equipment with EDDs carries potential safety concerns including the potential increase in a facility's vulnerability to hazards from undetected EDD defects, potential increase in susceptibility to electromagnetic interference and other potential hazards from the in service environment.



Processor for ABB Flow Transmitter



Basic Analog Input Layout



Differential Current Input



Basic Analog Input Configuration

-10 to +10 V

0 to +5V

0 to +10V

0 to 20 mA

Module Properties Report: Rack04:0 (1756-IF16 1.5)

General | Connection | Module Info | Configuration* | Alarm Configuration | Calibration | Backplane

Channel: 0 1 2 3* 4 5 6 7

Input Range: 0 ma to 20 ma

Sensor Offset: 0.0

Digital Filter: 0 ms

Scaling

High Signal: 20.0 ma = High Engineering: 100.0

Low Signal: 4.0 ma = Low Engineering: 0.0

RTS: 100 ms

Module Filter (-3 dB): 60 Hz

Status: Running

OK Cancel Apply Help

Module Properties Report: Rack04:1 (1756-IF16 1.5)

General | Connection | Module Info | Configuration* | Alarm Configuration | Calibration | Backplane

Channel: 0 1 2 3 4 5 6 7*

Input Range: 0 V to 10 V

Sensor Offset: 0.0

Digital Filter: 0 ms

Scaling

High Signal: 10.0 V = High Engineering: 10.0

Low Signal: 0.0 V = Low Engineering: 0.0

RTS: 100 ms

Module Filter (-3 dB): 60 Hz

Status: Running

OK Cancel Apply Help

Module Properties Report: Rack05:3 (1756-IF16 1.5)

General | Connection | Module Info | Configuration* | Alarm Configuration | Calibration | Backplane

Channel: 0 1 2 3 4 5 6 7

Input Range: 0 V to 5 V

Sensor Offset: 0.0

Digital Filter: 0 ms

Scaling

High Signal: 5.0 V = High Engineering: 4095.0

Low Signal: 1.0 V = Low Engineering: 0.0

RTS: 100 ms







Module Filter (-3 dB): 60 Hz

Status: Running

OK Cancel Apply Help

Eng. Units
Input Signal
Counts, 12 Bit

Basic Analog Input Code



Basic Analog Output Configuration

Module Properties Report: Rack04:6 (1756-OF6CI1.12)

General Connection Module Info Configuration Output State Limits Calibration Backplane

Channel: 0 1 2 3 4 5 Ramp Rate: 0.00 per Sec

Output State in Program Mode:
☐ Hold Last State
☒ User Defined Value: 4.0
☐ Ramp to User Defined Value

Output State in Fault Mode:
☒ Hold Last State
☐ User Defined Value:
☐ Ramp to User Defined Value

Communications Failure When communications fail in Program Mode:
☐ Leave outputs in Program Mode state
☒ Change outputs to Fault Mode state

Status: Running OK Cancel Apply Help

Module Properties Report: Rack04:6 (1756-OF6CI1.12)


General Connection Module Info Configuration Output State Limits Calibration Backplane

Channel: 0 1 2 3 4 5 Sensor Offset: 0.0


Scaling:
High Signal: 20.0 ma High Engineering: 4095.0
Low Signal: 4.0 ma Low Engineering: 0.0

☐ Hold for Initialization



Status: Running OK Cancel Apply Help



Basic Digital Relay Output



Basic Digital 24 V Input




Off State Voltage Max 5 V

IN-12- OFF, 0V or ON, 24V

IN-13- 1 mA, 3V or 4 mA, 12V,

IN-14- OP, 0V or CL, 24V

Basic HMI Screen Display



Numeric Display Properties

General Common

Expression

{COLD_BOX\PI406}

If... Logical... Relational... Arithmetic... Bitwise... Functions... Tags... Check Syntax Alarms...

Field Length: 3 Format: Decimal Leading Character: ☒ Blanks ☐ Zeroes Justification: ☐ Left ☐ Center ☒ Right

Decimal Places: 0 Overflow: Fill with asterisks

OK Cancel Apply Help

Tag

Name: COLD_BOX\PI406

Type: Analog Security: *

Description: HX2 Outlet Pressure

Minimum: 0 Scale: 1 Units: PSIA

Maximum: 500 Offset: 15 Data Type: Integer

Data Source

Type: ☒ Device ☐ Memory

Address: [NIST40PLC]N60[24]

Close Prev Next New Help Alarm...


Numeric Display Properties

General Common

Expression

{COLD_BOX\PI406} -14.7

Basic HMI Screen Display



Conclusion

Our Comm Fault appears to be a Common Cause Failure Associated with either Software or Firmware

Cold Source is not a Safety Related System

Use of Embedded Digital Devices Going Forward Will be Unavoidable

Questions?